



GMP Milton Solar RFP

Update to Clarify Interconnection Demarcation

Posted November 29, 2017

The demarcation point between GMP and EPC responsibilities is at the GMP MTC Cabinet shown by the Electrical Single Line diagram on page 1 as Item #8.

EPC will be responsible for installing conduit and conductor to the GMP MTC Cabinet. EPC will also provide the appropriate elbows for connecting to the GMP MTC cabinet.

GMP will be responsible for installing the cabinet and vault and will make the required connections to the MTC Cabinet.